

Water Analysis Report

شركة المياه الوطنية
National Water Company



Specification	Deputy Ministry for water - March 2021
Date of Analysis	WEDNESDAY -14-JUL-2021
Laboratory	Branch laboratories
Sender	Network

Sample number	25	26	27			
Source of sample	خزان علوي / مدرسة المنار	خزان سفلي / مدرسة المنار	عينة داخلية / مدرسة المنار			
Psychic determination	Unit	Uncertainty	Limes	Result sample25	Result sample26	Result sample27
PH	----	> 1	6.5 - 8.5	8.5	8.47	8
TDS	mg/L	< 10	100 - 1000	165	173	168
Free residual chlorine	mg/L	> 1	0.2 - 0.5	0	0	0
Conductivity	µS	< 10	-	300	314	305
Temperature	°C	---	-	25	25	25
Turbidity	NTU	> 1	0.5	0.16	0.09	0.25
Colour	PtCo	> 1	< 15	NON	NON	NON
Taste	---	---	NONE	NON	NON	NON
Odor	---	---	NONE	NON	NON	NON
Microbiological	Unit	Limes	Result sample25	Result sample26	Result sample27	
Total coliform	cfu/100ml	NONE	0	0	0	
F.coli	cfu/100ml	NONE	0	0	0	

Samples Collector		Prepared BY	
Name	Sajer Ayad	Name	ZIYAD AL JOHANI
Signature		Signature	
Water Analysis Laboratory Section Head			
Name	Badr Abdulaziz Shaqroun		
Signature			
Laboratories Manager			
Name	Bakur Emad Kurdi		
Signature			

